## **BSI-Inspectorate America** 178 Mortland Road Searsport, Maine 04974 (207)548-6440



## QUALITY CERTIFICATE

Vessel Customer Operation SHORE TANK NO. 3

**SPRAGUE** ANALYSIS Port Date

Terminal

BUCKSPORT, MAINE September 22, 2003

SPRAGUE

Report Reference

SP/03/0917

Sample # SEE BELOW

Name of material being tested Description of sample source Samples Drawn by (company) Samples Tested by (company)

## NO. 6 FUEL OIL 0.5%

EX. SHORE TK NO. 3 AFTER AGITATOR 9/21/03 INSPECTORATE INSPECTORATE

Tests being Performed		Test method	Minimum Maximum	Sample Source
SULPHUR, % WT.		ASTM D 4294		мунуу манда катанан (Мантин Ванда ) - Во 1 Английн байгайн ба
UPPER LEVEL	287541	ASTM D 4294		0.510
MIDDLE LEVEL		ASTM D 4294		0.506
LOWER LEVEL		ASTM D 4294		0.507
	201040			
		•		
			magan maticizi producio de la Proposicio Proposicio de la Companio de La Companio de La Companio Proposicio Proposici	

**DENNIS E. CURTIS** 

Inspectorate America Corp (Searsport, Me.)